



GENERAL NOTES FOR ALL DETAILS:

1. Only one inside drop per manhole.
2. PVC shall be ASTM D3034 SDR36.
3. See Std. Drg. RD336 for manhole steps details.
4. See Std. Drg. RD336 for tracer wire details.
5. All connecting pipes shall have a flexible, gasketed, and unrestrained joint within 18" of manhole wall.
6. See appropriate manhole standard drawings for details not shown.

BASELINE REPORT DATE: _____
 NOTE: All material and workmanship shall be in accordance with the current Oregon Standard Specifications.

OREGON STANDARD DRAWINGS

**SANITARY SEWER
 PIPED INSIDE DROP CONNECTION
 FOR MANHOLES**

2008
 REVISION DESCRIPTION

DATE: _____

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.

SECTION A-A
 CLAMP DETAIL

Effective Date: June 1, 2011 - November 30, 2011 RD350