



NOTES:

1. DROP MANHOLES SHALL ONLY BE USED WITH PRIOR APPROVAL FROM CITY OF WINSTON.
2. FOLLOW RELINER INSTRUCTIONS FOR INSTALLATION.
3. SEE STD DWG RD336 FOR MANHOLE STEPS DETAILS.
4. SEE STD DWG RD336 FOR TRACER WIRE DETAILS.
5. ALL CONNECTING PIPES SHALL HAVE A FLEXIBLE, GASKETED, AND UNRESTRAINED JOINT WITHIN 18" OF MANHOLE WALL.
6. ONLY ONE DROP ASSEMBLY ALLOWED PER MANHOLE.

NOTES:

1. THIS DETAIL HAS BEEN MODIFIED BY THE CITY OF WINSTON. ALL MATERIAL AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH THE CURRENT OREGON STANDARD SPECIFICATIONS.



WINSTON STANDARD DRAWING

**SANITARY SEWER MANHOLE
INSIDE DROP**