


SECTION B-B



KEYWAY DETAIL

NOTES:

1. INLET TOP MAY BE CAST-IN-PLACE OR PRECAST. ALL PRECAST INLETS SHALL CONFORM TO THE REQUIREMENTS OF ASTM C913.
2. ALL REINFORCEMENT SHALL BE 2" CLEAR OF NEAREST FACE OF CONCRETE UNLESS OTHERWISE SHOWN.
3. VARY ANCHOR BOLT LENGTH AND REINFORCING BAR PLACEMENT AS REQUIRED BY CURB EXPOSURE E.



NOTES:
1. THIS DETAIL HAS BEEN MODIFIED BY THE CITY OF WINSTON. ALL MATERIAL AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH THE CURRENT OREGON STANDARD SPECIFICATIONS.

WINSTON STANDARD DRAWING

CURB INLET TOP